

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7120-1429:103 Page 1 of 1

**CATEGORY:** Annunciators

**LISTEE:** Secutron Inc., 3301 Langstaff Rd, Concord, Canada, L4K 4L2  
Contact: Paul Mattern (978) 731-8542 Fax (978) 731-8881

**DESIGN:** Model MR-2614, MR-2944, \*MR-2644G and \*MR-2644R Remote Annunciators. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

MR-2614	Basic Board
MR-2614EH	Enhanced Board
MR-2622/-2902	Annunciator Strip
MR-2915	LED Driver
MR-2944/-2944LC/-2944LCD	Driver Board
MR-2910-X	Communication Board
* MR-2644-SMR	Enclosure for MR-2644R
* MR-2644-SMG	Enclosure for MR-2644G

**RATING:** 24 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical ratings, and UL label.

**APPROVAL:** Listed as remote annunciators for use with separately listed compatible fire alarm control units. Model MR-2400 (CSFM Listing No. 7165-1429:102) and MR-2900 (CSFM Listing No. 7165-1429:100) Fire Alarm Control units. Refer to listee's Installation Instructions Manual for details.

\*Rev. 1-08-2003KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 17, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager